



## FIRE RESISTANT TIMBER FIRE DOORS

Certificate number: IFCC 1695

Certificate only valid if verified on website – [www.ifccertification.com](http://www.ifccertification.com)

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

### ***K. Lambrianou & Sons Ltd***

Andrea Zakou No. 14  
Aradippou Industrial Area  
7101 Aradippou  
Larnaca  
Cyprus  
Telephone no. +357 24 533676

Who fabricate the following timber fire doors and or doorsets:

**Halspan EI30, EI30Sa Halspan EI60, EI60Sa  
Strebord EI30, EI30Sa, Strebord EI60, EI60Sa**

have satisfied the requirements of the SDP01 Fire Resistant Timber Door scheme. This includes the testing of products to **EN1634-1** the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve from **30 minutes to 60 minutes integrity & insulation** are detailed in the schedules referenced below.

Schedule refs: BMT/CAN/F13020, BMT/FEA/F13021, BMT/CNA/F14053, BMT/CNA/F14054

Initial Certification: 21 January 2022

Reissued: 21 April 2023

Valid to: 20 January 2024

Issue number: 2

Ian Woodhouse  
Head of Technical – IFC Certification  
Kiwa Ltd

*This certificate consists of 1 page.  
Publication of this certificate is permitted.*