



## FIRE RESISTANT TIMBER GLAZED SCREENS

Certificate number: IFCC 1252

Certificate only valid if verified on website – [www.ifccertification.com](http://www.ifccertification.com)

Issued by IFC Certification Ltd part of the Kiwa UK Group

This is to certify that

### K. Lambrianou & Sons Ltd

Andrea Zakou No. 14  
Aradippou Industrial Area  
7101 Aradippou  
Larnaca  
Cyprus  
Telephone no. +357 24 533676

Who fabricate timber fire resisting elements with the following glasses:

**Pyrobelite 7, Pyrobelite 7 EG, Pyrobelite 10, Pyrobelite 12,  
Pyrobel 16, Pyrobel 16 EG, Pyrobel 25, Pyrobel 25 EG**

have satisfied the requirements of the Glazing Scheme SDP 09 v1.2. This includes the testing of products to **BS476: Part 22: 1987, BS EN1363-1: 2020 or BS EN 1364-1: 2015**, as appropriate, the inspection of Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specifications and fields of application to achieve from **30 mins to 60 mins integrity** are detailed in the schedule referenced below. As this certificate invokes CF377 it cannot remain valid after the expiry date of CF377.

Schedule ref: IFCC1252/S01

Initial Certification: 31 July 2016

Revised: 14 April 2025

Valid to: 18 March 2026

Issue Number: 9

David Mowatt  
Head of Certification – IFC Certification /  
KIWA Group Limited

*This certificate consists of 1 page.  
Publication of this certificate is permitted.*

